



PRODUCT CERTIFICATE

No.: CQC16003142025

NAME AND ADDRESS OF THE APPLICANT

Xiamen WAIN Electrical Co., Ltd.
Chengbei Industrial Zone, Datong Street, Tong'an District, Xiamen City

NAME AND ADDRESS OF THE MANUFACTURER

Xiamen WAIN Electrical Co., Ltd.
Chengbei Industrial Zone, Datong Street, Tong'an District, Xiamen City

NAME AND ADDRESS OF THE FACTORY

Xiamen WAIN Electrical Co., Ltd. (V024557)
No.759-3 Chengbei Industrial Zone, Chaoyuan Road, Tong'an District, Xiamen

NAME, MODEL AND SPECIFICATION

Electrical Connectors

Model See Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC11-462222-2011.

Date of issue: Apr.11,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0083310



产品认证证书

附录:

第 1 页 共 1 页

证书编号: CQC16003142025

纸号: 83310

产品名称 (中文):

电连接器

规格和型号:

HE-048-MSS+HE-048-FSS 16A 500V IP65
HME-005-MS+HME-005-FS 16A 400V IP65;
HE-006-MS+HE-006-FS 16A 500V IP65;
HE-006-MSS+HE-006-FSS 16A 500V IP65;
HE-010-MS+HE-010-FS 16A 500V IP65;
HE-010-MSS+HE-010-FSS 16A 500V IP65;
HE-016-MS+HE-016-FS 16A 500V IP65;
HE-016-MSS+HE-016-FSS 16A 500V IP65;
HE-024-MS+HE-024-FS 16A 500V IP65;
HE-024-MSS+HE-024-FSS 16A 500V IP65;
HE-032-MS+HE-032-FS 16A 500V IP65;
HE-032-MSS+HE-032-FSS 16A 500V IP65;
HE-048-MS+HE-048-FS 16A 500V IP65。

无分断能力 固定连接器 I 类 不带联锁 螺纹端子连接 -40T125 污染等级 3 无负载 500
次操作循环 灼热丝 850℃ 球压 125℃ 针焰 10s PTI175

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>